



15		
14		
13		
12	Ball Valve	1
11	Pressure & Temperature Valve	1
10	Automatic 3-Way Zone Valve	1
9	Set Point Controller	1
8	1/2" Threaded Bronze Tee	4
7	Potable Expansion Tank, Flex Tube & Mounting Bracket	1
6	Radiator	1
5	SolarHOT 4 x 8' Platinum Collectors	8
4	Manual Air Vent	1
3	Check Valve	1
2	ASSE 1017 Certified Mixing Valve	1
1	Solvelox Heat Exchange System - Glycol	1
ITEM	DESCRIPTION	QTY

1 Recommended install heat trap on cold inlet and hot supply to mixing valve, 8" minimum.

Copyright by:

REVISIONS

NO.	REVISION	DATE	BY
1			
2			
3			

	DRAWN BY Jessica Gretsch	DESCRIPTION Double Tank Glycol System
	DATE 6/1/2009	THE DRAWING CREATED WITH AECO
TYPED FILE PRESENTATION	SHEET 1 OF 1	APPROVED BY NTS DATE D
TOLERANCES UNLESS OTHERWISE SPECIFIED FRACTIONS DECIMALS ANGLES DIMENSIONS FINISHES PRECEDENCE	<b>SCHEM0075</b>	